

GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 1 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

620 Old Peachtree Road NW, Suite 100, Suwanee, GA 30024 USA (770) 570-1800

Test Report Number: CQES240100003461

A representative sample of the product covered by this report has been evaluated and found to comply with the applicable requirements of Standard for Safety for Batteries for Use in Stationary and Motive Auxiliary Power Applications, ANSI/CAN/UL 1973, Third Edition, Dated February 25, 2022.

This report supersedes and replaces previous copies of same project number.

Issuing Laboratory:	SGS-CSTC Standards Technical Services Co., Ltd. Shenzhen Branch		
Address:	No. 1 Workshop, M-10, Middle Section, Science & Technology Park, Shenzhen, Guangdong, China		
Applicant (Certificate Holder):	GoodWe Technologies Co., Ltd.		
Address:	No. 90 Zijin Road, New District, Suzhou, 215011, Jiangsu, China		
Contact Details:	Xiaoshu Huan		
	Phone: +86 18261533751		
	Email: xiaoshu.huan@goodwe.com		
Manufacturer	GoodWe Technologies Co., Ltd.		
Address:	No. 90 Zijin Road, New District, Suzhou, 215011, Jiangsu, China		
Contact Details:	Xiaoshu Huan		
	Phone: +86 18261533751		
	Email: xiaoshu.huan@goodwe.com		
Factory 1:	Goodwe (Guangde) Power Supply Technology Co., Ltd.		
Address:	No. 8, Dongting Rd., Guangde Economic Development Zone, Anhui, China		
Contact Details:	Xiaoshu Huan		
	Phone: +86 18261533751		
	Email: xiaoshu.huan@goodwe.com		



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 2 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

Product Type	Rechargeable lithium-ion battery system						
Trade Mark:	GOODWE						
Product description:	Lithium-ion battery sys	tem					
	(Product name: Rechargeable Li-ion Battery system)						
	For both indoor use an	nd outdoor u	ıse.				
Model Number(s)	LX F9.6-30, LX F12.8	-30, LX F16	6.0-30, LX F	19.2-30			
Model Differences:	All models have the same basic module, model: LX F3.2-30, and the same high voltage control box, the only difference is the number of modules for each system. Model LX F9.6-30, model LX F12.8-30, model LX F16.0-30 and model LX F19.2-30 has 3, 4, 5, 6 basic battery modules respectively.						
Electrical Ratings	Model	LX F9.6- 30	LX F12.8- 30	LX F16.0- 30	LX F19.2-30		
	Rated Voltage, V	192	256	320	384		
	Rated Capacity, Ah	50	50	50	50		
	Rated Capacity, kWh	9.6	12.8	16.0	19.2		
	Operating voltage range, V	171-216	228-288	285-360	342-432		



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 3 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

Other Ratings						
	Models	LX F9.6-30, LX F12.8-30, LX F16.0-30, LX F19.2-30				
	Max. charging current, A	35				
	Max. discharging current, A	35				
	Charging Temperature range (ambient), °C	0 - 50				
	Discharging Temperature range (ambient), °C	-15 - 50				
	Altitude, m	3000				
	IP Rating	IP65				
Accessories	N/A					
Testing Laboratory 1	SGS-CSTC Standards Technical S Branch	Services Co., Ltd. Shenzhen				
Address 1	No.2, Jianghao Industrial Factory A Bantian Street, Longgang District,					
Testing Laboratory 2:	SGS-CEC New Energy Technolog	y (Chongqing) Co., Ltd				
Address 2:	Building 13 &14, No. 1839, Ranjun District, Chongqing, China	Road, Shuangfu Street, Jiangjin				
Testing Laboratory 3::	Compliance Certification Services	(Kunshan) Inc.				
Address 3:	No.10 Weiye Rd, Innovation park, Kunshan City, Jiangsu, China	Eco&Tec, Development Zone,				
Date of receipt of test item:	2024-07-10 (Original date: 2022-06-08, 2022-12-07, 2024-01-10)					
Date(s) of performance of tests:	2024-07-11 (Original date: 2022-07-08 to 2022-08-29, 2022-12-08 to 2023-01-10, 2024-01-16 to 2024-03-15)					
Certification Conditions (X Condition)	N/A					



GoodWe Technologies Co., Ltd.

Page 4 of 55
PROJECT NUMBER: SZ-CERT240401415

Issued: 18 Apr. 2024
Revised 03: 29 Apr. 2025

		Revised 03: 29 Apr. 2
Component Conditions	1.	The enclosure of battery system was evaluated to establish an
(U Condition)		IP rating of IP65 with the Standard for Degrees of Protection Provided by Enclosure (IP Code), IEC 60529.
	2.	The lithium-ion battery system provided one grounding screw in high voltage control box to be grounded through grounding conductors to the earth in the end installation. The lithium-ion battery system has been subjected to ground continuity test only between the metal enclosure and grounding screw of pack, grounding conductors between the grounding screw of the pack to the earth should be provided in the end installation and the acceptance of the continuity of the whole grounding system should be determined in the end application.
	3.	The maximum configuration of battery system, model LX F19.2-30, is 6 modules and the high voltage control box. It's only investigated for the series connection, not for parallel connection. The maximum voltage of battery system is 432 Vdc the spacings requirement shall be considered if series connected more than 6 modules in the end use application.
	4.	The instructions for the proper installation and use including charging and discharging, storage, recycling and disposal shall be required for the end use application. These instructions shall include temperature limits, charging and discharging limits as well as instructions regarding the use of any controls or monitoring systems.



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 5 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

CO-LISTING PAGE

CO-LISTING APPLIC	CANT I		
Applicant's Name:		·	
Address:			
Primary Contact:			
Phone:			
Fax:			
Email:			
Product Correlation	<u>:</u>		
Basic Models	Co-Listed Models	Note any differences between Basic and Co-Listed models	
CO-LISTING APPLIC	CANT II		
Applicant's Name:			
Address:			
Primary Contact:			
Phone:			
Fax:			
Email:			
-			
Product Correlation	i		
Basic Models	Co-Listed Models	Note any differences between Basic and Co-Listed models	



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

Page 6 of 55

GENERAL INFORMATION

Components

Components used in the covered products must be those outlined in the latest edition of the Listing Report.

Listing Marking

This report along with a valid certificate authorizes the certificate holder to use the Listing Marking of SGS North America only on products covered by this report and in accordance with the Product Certification Program Policy Handbook.

Production Line Tests

Manufacturing and Production Tests shall be performed as required by this Report.

Responsibility of the Manufacturer and Factory

- It is the manufacturer and factory's responsibility to restrict the use of markings which reference SGS to those
 products which are found by the manufacturers own inspection to comply with the product description in this
 report. This includes reference to SGS directly and/or indirectly.
- 2) During hours in which the factory is in operation, the SGS inspector shall be given unlimited access to any portion of the premises where the product and/or parts are being produced, assembled, inspected and labeled; and to the test area designated for routine tests. The SGS inspector shall be permitted to inspect and subject the products to prescribed tests prior to shipment any product bearing or intended to bear marking referencing SGS.
- 3) The factory shall provide all required testing equipment and facilities including trained personnel for conducting all routine tests that are to be performed at the factory. These shall be available when needed so that the inspection work can proceed without delays.



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

Page 7 of 55

Follow up Inspections

As part of the SGS Follow-Up inspection, it is required that an inspector periodically visit the factory location(s) and select for examination and/or testing, the most recent production sample of the product covered in the Listing Report.

SGS Inspector

- A product which is found by the SGS inspector to have features which make it unacceptable to bear marking referencing SGS shall be corrected if the listing marking is to be used. The inspector shall carefully check additional production for such features until conditions are considered normal.
- 2) A product which does not comply with the provisions of the listing report shall have all reference to SGS removed. If the rejection of the product is questioned by the factory representative, it may be put on hold in separate area of location pending appeal. The factory shall satisfy the inspector that all marks referencing SGS are removed from the rejected material or finished product. Factory shall destroy product and or turn over to inspector for destruction.
- 3) All discrepancies between the product and the listing report shall be immediately stated to the attention of the factory representative. This shall be noted in the follow-up inspection report as a discrepancy.



GoodWe Technologies Co., Ltd. Page 8 of 55 PROJECT NUMBER: SZ-CERT240401415 Issued: 18 Apr. 2024

Revised 03: 29 Apr. 2025

GENERAL CONSTRUCTIONAL REQUIREMENTS TO BE VERIFIED

<u>Construction Details</u> - This section specifies construction and component details in addition to the critical components table which are to be verified during factory follow-up inspections. Details or photos shall be provided here on any specific areas the inspector shall verify on the production line.

Electrical Drawings – The following table lists the electrical drawings (Schematics, BOM, PCB Layout) used during evaluation.

Item No.	Drawing Title	Drawing Number	Revision	Date (mm/dd/yy)
1	Bom of BCU	BCU-B30-202-002	V2.4	01/05/2023
2	Schematic of BCU	BCU-B30-202-002	V1.2	06/27/2022
3	PCB Layout of BCU	BCU-B30-202-002	V1.2	06/27/2022
4	Bom of BMU	BMU-B30-24-204	V1.5	06/27/2023
5	Schematic of BMU	BMU-B30-24-204	V1.4	11/01/2021
6	PCB Layout of BMU	BMU-B30-24-204	V1.4	11/01/2021
7	Bom of DC/DC	290-50096	T0	12/08/2023
8	Schematic of DC/DC	290-50096	T0	12/08/2023
9	PCB Layout of DC/DC	190-50093	T0	12/07/2023



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 9 of 55 Issued: 18 Apr. 2024

Revised 03: 29 Apr. 2025

ROUTINE TESTS FOR MANUFACTURING AND PRODUCTION

The manufacturer shall perform the following Manufacturing and Production Tests on 100% of equipment produced which has both hazardous live parts and accessible conductive parts.

1, Active Controls Checked

Battery systems shall be subjected to 100% production screening to determine that any active controls utilized for safety are functioning.

2, Dielectric Voltage Withstand Test

As a routine production line test, each appliance shall be subjected either to a voltage of substantially sine-wave form having a frequency of 50 Hz or 60 Hz, or to a d.c. test voltage equal to the peak voltage of the prescribed a.c. test voltage, and shown in the table below:

The results are acceptable if there is no dielectric breakdown.

Test Point	Test Voltage	Test Time
Module +/- to Metal Enclosure of Module	2500 Vd.c.	Min. 1 second
System +/- to Metal Enclosure of high voltage control box	2500 Vd.c.	Min. 1 second
System +/- to communication circuit of BMU	4000 Vd.c.	Min. 1 second
System +/- to communication circuit of BCU	4000 Vd.c	Min. 1 second

3, Continuity Test

A continuity check of the grounding system using a milliohmmeter or other method, shall be conducted on 100% production employing protective grounding. The continuity check shall determine that measurements made on any two points of the grounding system do not exceed 0.1 Ω .

A visual or audible device (ohmmeter, buzzer, etc.) may be used to indicate grounding continuity.



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

PHOTOGRAPHS

External view of battery system, model LX F9.6-30

Page 10 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

PHOTO NO. 1-2







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

External view of battery system, model LX F12.8-30

Page 11 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 3-4







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

External view of battery system, model LX F16.0-30

Page 12 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 5-6







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

External view of battery system, model LX F19.2-30

Page 13 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 7-8







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Base of Battery System

Page 14 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 9-10







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

External view of basic battery module, model: LX F3.2-30

Page 15 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 11-12







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Internal view of basic battery module, model: LX F3.2-30

Page 16 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 13-14







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

External view of high voltage control box

Page 17 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 15-16







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Internal view of high voltage control box

Page 18 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 17-18









GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

External view of BCU box

Page 19 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 19-20









GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

View of PCBA of BCU

Page 20 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 21-22








GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

View of DC/DC Module

Page 21 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 23-24








GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

View of Transformer of DC/DC Module, Model 140-00193-00 by Lianfeng

Page 22 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 25-26









GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

View of Transformer of DC/DC Module, Model 140-00193-00 by JTK

Page 23 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 27-28







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

External view of Basic Battery Module Sub-Control Box

Page 24 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 29-30









GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

View of PCBA of Basic Battery Module Sub-Control

Page 25 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 31-32









GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

View of Cell

Page 26 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025 PHOTO NO. 33-34







GoodWe Technologies Co., Ltd. Issued: 18 Apr. 2024 PROJECT NUMBER: SZ-CERT240401415 Revised 03: 29 Apr. 2025 Wall mounting schematic diagram Install two M5 flange nuts and two M5 hex bolts each, and operate the same on the other side Install two M5 hex socket bolts, Same operation on the other side 0000000 0000000 The hole at the arrow position needs to be installed with expansion screws M8 or self drilling screws M8 and fixed on the wall 0000000 0000000 0 0 0 0 000000 0000000 0 0 0 0 0000000 0000000 0000000 0000000 0mm≤Distance 000000 from the ground

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at https://www.sgs.com/en/terms-and-conditions and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at https://www.sgs.com/en/terms-and-conditions/terms-e-document. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained

≤ 150mm

Page 27 of 55

PHOTO NO. 35-36



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 28 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

CRITICAL COMPONENTS

The following components are considered "critical" in terms of this certification and must be verified during factory inspections. No substitutions or alternate components are allowed unless specifically as stated in this report.

Photo No.	Item No.	Component name	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity
	1	Marking label	Interchangeable	Interchangeable	Min. range (min. temp -20 °C, max temp 80 °C), suitable for adhering on SPCC surface	UL 969, CSA C22.2 No. 0.15	UR
1-8	2	Metal enclosure	Interchangeable	Interchangeable	SPCC: Min. thickness: 1.2 mm		*
	3	Seal rings for metal enclosure	SuZhou Jin Teng Electronics Co Ltd	JTR1795-1800	Ambient Service Temperature Range: -50 °C – 150 °C	UL 157	UR (MH65658)
	4	Coating for metal enclosure	AkzoNobel Coatings S.L.U.	Interpon D1036	Red, white, and black colors only. Min. dry film thickness 0.0015 in.	UL 1332	UR (MH26202)
	5	Insulation Tube	Interchangeable	Interchangeable	Min. 105 °C, VW-	UL 224, CSA-C22.2 No. 198.1 (2006)	UR
	6	Insulation Tube	Interchangeable	Interchangeable	Min. 105 °C, VW-	UL 1441, CSA-C22.2 No. 198.3	UR
	7	Signal Wiring	Interchangeable	Interchangeable	Min. 80 °C, Min. 300 V, Min. 22 AWG	UL 758, CSA-C22.2 No. 127	UR
	8	Power Wiring	WUXI XINHONGYE WIRE & CABLE CO LTD	10269	105 °C, 1250 Vdc, 8 AWG	UL 758, CSA-C22.2 No. 127	UR (E248566)
	8a	Power Wiring (Alt.)	Interchangeable	Interchangeable	Min. 105 °C, Min. 750 Vdc, Min. 8 AWG	UL 758, CSA-C22.2 No. 127	UR



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 29 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

						revised oo.	29 Apr. 2020
	9	Power Connector	AVIC JONHON OPTRONIC TECHNOLOGY CO., LTD	DLA21T-YY, DLA21Z-YY	1500 V, 35 A, - 55 °C – 125 °C	UL 1977, CSA-C22.2 No. 182.3	UR (E203642)
	10	Black Signal Connector of PCBA (J1, J2, JV1~JV3)	LOTES CO LTD	AAUS01AP2	3 A, -40 °C to 85 °C	UL 1977, CSA-C22.2 No. 182.3	UR (E187055)
	10a	Black Signal Connector of PCBA (J1, J2, JV1~JV3) (Alt.)	Interchangeable	Interchangeable	3 A, -40 °C to 85 °C	UL 1977, CSA-C22.2 No. 182.3	UR
21-24, 31, 32	11	PWB	KUNSHAN HUATAO ELECTRONICS CO LTD	HT-D	V-0, 130 °C	UL 796, CSA C22.2 No. 0.17	UR (E318580)
	11a	PWB (Alt.)	Interchangeable	Interchangeable	V-0, 130 °C	UL 796, CSA C22.2 No. 0.17	UR
Battery	Pack,	Model LX F3.2-3	0				
33, 34	12	Cell	REPT BATTERO Energy Co., Ltd.	CB3914895EA	3.2 V, 50 Ah (20S1P)	ANSI/CAN/ UL 1973:2022	CSA MASTER CONTRAC T: 301650, REPORT: 80064143
	13	Busbar	Interchangeable	Interchangeable	AL1060, 140 A, Minimum thickness:1.5 mm		*
	14	Orange Plastic insulator of sub- module terminals	Interchangeable	Interchangeable	Min. V-2, min. 80 °C	UL 94, UL 746, CSA C22.2 No. 0.17	UR
	15	Black Plastic cover of sub- module	Interchangeable	Interchangeable	Min. V-2, min. 80 °C	UL 94, UL 746, CSA C22.2 No. 0.17	UR
	16	Insulation Tape	Interchangeable	Interchangeable	Min. 105 °C	ANSI/CAN/ UL 510A	UR
	17	Epoxy board	Interchangeable	Interchangeable	Min. V-2, min. 80 °C, min. thickness 1 mm	UL 94, UL 746, CSA C22.2 No. 0.17	UR



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 30 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

	18	Yellow Power Connector	Changzhou Amass Electronics Co Ltd	ХТ90H-F, ХТ90H-М	500 V, 30 A	UL 1977, CSA-C22.2 No. 182.3	UR (E482722)
	19	Black Module Connector	Interchangeable	Interchangeable	V-2, 80 °C	UL 1977, CSA-C22.2 No. 182.3	UR
	20	NTC Sensor	THINKING ELECTRONIC INDUSTRIAL CO LTD	TSM1A103	10 kohm at 25 °C, T _{moa} 125 °C	UL 1434 or UL60730- 1, CAN/CSA- E60730-1	UR (E138827)
27, 28	21	Battery Manage Unit (BMU)	Hangzhou Xieneng Technology Co., Ltd.	BMU-B30-24- 204-000-001			*
	21-1	Enclosure of BMU	FORMOSA CHEMICALS & FIBRE CORP PLASTICS DIV	AC310(+)	V-0, 85 °C, min. thickness 1.5 mm	UL 94, UL 746, CSA C22.2 No. 0.17	UR (E162823)
	21-2	Transformer (TJ4)	SHENZHEN SINODRIVE ELECTRIC TECHNOLOGIE S CO., LTD	N12105S	-40 °C to +125 °C, 1600 VDC	UL 62368- 1, CAN/CSA- C22.2 No. 62368-1	UR (E523028)
	21-3	AFE (U1_V1, U1_V2)	ADI	ADBMS6815	0 V ~ 5V, -40 °C to 125 °C		*
	21-4	Balanced resistance (RV99_V1, RV101_V1, RV105_V1, RV109_V1, RV111_V1, RV113_V1, RV117_V1, RV119_V1, RV123_V1, RV99_V2, RV101_V2,	UNI-ROYAL	25121WF430JT 4E	22 Ω, 1 W, 1%		*



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 31 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

		RV103_V2, RV105_V2, RV107_V2, RV109_V2, RV111_V2, RV113_V2, RV115_V2, RV117_V2, RV119_V2, RV121_V2, RV123_V2)	I DOLL FOR				
High-vo	mage c	control box, Mode	PCU-FZ1				
	22	Film indicator	SABIC INNOVATIVE PLASTICS B V	9030(f1)(m)	HB, Min. 1.5 mm thickness, 125 °C	UL 94, UL 746C, CSA C22.2 No. 0.17	UR (E45329)
	22a	Film indicator (Alt.)	TEIJIN LIMITED RESIN AND PLASTIC	L-1250U(#)(f1)	V-2, Min. 0.84 mm thickness, 115 °C	UL 94, UL 746C, CSA C22.2 No. 0.17	UR (E50075)
	23	Seal rings for Film indicator	SuZhou Jin Teng Electronics Co Ltd	JTR1795-1800	Ambient Service Temperature Range: -50 °C – 150 °C	UL 157	UR (MH65658)
	24	Breaker Cover	CHI MEI CORPORATION	PC-6710(f1)(a)	V-0, 120 °C, minimum thickness 3.0 mm	UL 94, UL 746C, CSA C22.2 No. 0.17	UR (E56070)
	25	Circuit Breaker	NOARK ELECTRIC USA INC	Ex9BP	600 Vdc, 50 A	UL 1077, CSA-C22.2 No. 235	UR (E355391)
	26	Stuffy Cover and Vent Valve	BASF SE	A3UG5 (t)(f1)	5VA, 90 °C, minimum thickness 1.5 mm	UL 94, UL 746C, CSA C22.2 No. 0.17	UR (E41871)
	27	Main Relay	SHANGHAI LIANGXIN ELECTRICAL Co., Ltd.	NDZ3T-40	750 Vdc, 40 A, -40 °C - 85 °C	UL 508, CSA-C22.2 No. 14	UR (E514982)
	28	Pre-charge Relay	Y M TECH	EVR10-24S	750 Vdc, 10 A, -40 °C - 85 °C	UL 508, CSA-C22.2 No. 14	UR (E210800)



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 32 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

						11011300 00.	29 Apr. 2020
	29	Terminal Block	SHENZHEN CONNECTION ELECTRONIC CO LTD	DRTB16- R60(54)	600 V, 65 A, - 55 °C – 125 °C	UL 486	UR (E304128)
25, 26	30	Transformer (TX100)	Haining Lianfeng Dongjin Electronics Co., Ltd.	140-00193-00	Output 24 Vdc, 0.96 mH±10%, - 40 °C – +130 °C		*
	30-1	Bobbin	CHANG CHUN PLASTICS CO LTD	T375HF	Min. thickness 0,43 mm, V-0, 150 °C, CTI 3	UL 94, UL 746	UR (E59481)
	30-1	Bobbin (Alt.)	SUMITOMO BA KELITE CO LTD	PM-9630 PM-9820	Min. thickness 0,43 mm, V-0, 150 °C, CTI 3	UL 94, UL 746	UR (E41429)
	30-2	Triple Insulated Wire for Primary/Second ary	SHENZHEN KAIZHONG HEDONG NEW MATERIALS CO LTD	TIW-B*	130 °C, Class B	UL 2353	UR (E357240)
	30-2	Triple Insulated Wire for Primary/Second ary (Alt.)	KBI COSMOLIN K CO.,LTD	TIW-M	130 °C, Class B	UL2353	UR (E213764)
	30-3	Glue	DONG GUAN SHI PAI HUA CHUANG MATERIAL FTY	H907-HF-Z	Min. thickness 4,75 mm, V-0, 130 °C	UL 94, UL 746	UR (E304477)
	30-4	Tube	GREAT HOLDING INDUSTRIAL CO LTD	TFL	Max rms 150 V, Max Oper. Temp 200 °C	UL 224	UR (E156256)
	30-5	Varnishes	SUZHOU TAIHU ELECTRIC ADVANCED MATERIAL CO LTD	T-4260(a)	155 °C	UL 1446	UR (E228349)
	30-6	Tape	JINGJIANG YAHUA PRESSURE SENSITIVE GLUE CO LTD	CT* (c)(g)	130 °C	UL 510A	UR (E165111)



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 33 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

						11011000 00.	29 Apr. 2020
27, 28	30a	Transformer (TX100) (Alt.)	JTK TECHNOL OGY(SUZHOU) CO., LTD	140-00193-00	Output 24 Vdc, 0.96 mH±10%, - 40 °C - +130 °C		
		Bobbin	CHANG CHUN PLASTICS CO LTD	T375HF	Min. thickness 0.43 mm, V-0, 150 °C	UL 94 UL 746	UR (E59481)
		Triple Insulated Wire for Primary/Second ary	SU ZHOU YU S HENG ELECTRI C CO., LTD	TIW-B*	130 °C, Class B	UL 2353	UR (E332529)
		Triple Insulated Wire for Primary/Second ary (Alt.)	WUHU OULY E LECTRONICS C O., LTD	OLTIW-B*	130 °C, Class B	UL 2353	UR (E466302)
	30a-3	Glue	DONGGUAN EA TTO ELECTRO NIC MATERIAL CO., LTD	E-500(XX)	Min. thickness 3 mm, V-0,130 °C	UL 94 UL 746	UR (E218090)
	30a-4	Tube	CHANGYUAN E LECTRONICS G ROUP CO., LTD	CB-TT-L	Max rms 150 V, Max Oper Temp 200 °C	UL 224	UR (E180908)
	30a-5	Varnishes	SUZHOU TAIHU ELECTRIC ADVANCED MATERIAL CO LTD	T-4260(a)	155 °C	UL 1446	UR (E228349)
	30a-6	Таре	JINGJIANG YAH UA PRESSURE SENSITIVE GLU E CO LTD	PF*(d)(g)	180°C	UL 510A	UR (E165111)
	31	DC Link Capacitor (C2, C3)	XIAMEN FARATRONIC CO LTD	C3D	800 V, 10 μF ± 5%, -40 °C - 105 °C	ANSI/UL 810, CSA- C22.2 No. 190	UR (E256238)
	32	24 V DC Connector Enclosure (CN101)	Celanese (Suzhou) Engineering Plastics Co Ltd	A 63 R V0 (a)(b)(f2)	V-0, 105 °C, min. thickness 0.38 mm	UL 94, UL 746, CSA C22.2 No. 0.17	UR (E331274)
	33	Control MOS (Q100)	ONSEMI	FQP6N90C	900 V, 6 A		*



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 34 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

	34	Y Capacitor (C122)	Walsin Technology Corp	AH Series (#)(&) Y1	400 Vac, 4700 pF, Lower Temp - 40 °C, Upper Temp 125 °C	UL 60384- 14, CAN/CSA- E60384-14	UR (E146544)
	35	FUSE	ADVANCED SURGETECH MATERIALS LTD	A180701-80	DC 700V, 80 A	UL 248-1, CSA C22.2 No. 248.1	UR (E470032)
	36	Pre-charge resistor	VICTORY CHINA FAR EAST ELECTRONICS CO., LTD OF BENGBU	RX24	100 Ω, 75 W		*
	37	Current diverter	Anhui Laifu Electronic Technology Co.,Ltd	FL-2	75 mΩ, 75 A		*
	38	Button switch	ZHEJIANG QIANNIAN ELECTRONIC CO LTD	C-QN19-S	24 V, 1 A	UL 61058- 1, CSA- C22.2 No. 61058-1	UR (E489975)
	39	Signal Connector	Interchangeable	Interchangeable	250 V, 5 A	UL 1977, CSA-C22.2 No. 182.3	UR
	40	Red Insulation Block Interchangeable		Interchangeable	Min. V-2, min. 80 °C, min. height 35 mm	UL 94, UL 746, CSA C22.2 No. 0.17	UR
	41	Cover for Hole through power wiring	BASF SE	A3UG5 (t)(f1)	5VA, 90 °C, minimum thickness 1.5 mm	UL 94, UL 746, CSA C22.2 No. 0.17	UR (E41871)
19, 20	42	Battery Control Unit (BCU)	Hangzhou Xieneng Technology Co., Ltd.	BCU-B30-202- 002-001			*
	42-1	Enclosure of BCU	FORMOSA CHEMICALS & FIBRE CORP PLASTICS DIV	AC310(+)	V-0, 85 °C, min. thickness 1.5 mm	UL 94, UL 746C, CSA C22.2 No. 0.17	UR (E162823)



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 35 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

		Network transformer (TR2)	SHENZHEN SINODRIVE ELECTRIC TECHNOLOGIE S CO., LTD	N12105S	-40 °C to +125 °C, 1600 VDC	UL 62368- 1, CAN/CSA- C22.2 No. 62368-1	UR (E523028)
	42-3	Optical Isolators (UH1, UH2)	Panasonic Industry Co., Ltd.	AQV	5000 Vac, -40 °C to 85 °C	UL 1577	UR (E191218)
		Communication isolation chip (U13, U14, U15)	Suzhou Novosense Microelectronics Co., Ltd	NSI82xxWx- DSWR	5000 Vac, -40 °C to 125 °C	UL1577	UR (E500602)
	42-5	MCU (U6)	ST	STM32F407ZGT 6	1.8 V ~ 3.6 V, - 40 °C to 85 °C		*
	42-6	Communication chip (UN3, UN5)	ЗРЕАК	TP1051V	3 V ~ 5.5 V, - 40 °C to 125 °C		*
	42-7	AFE (U17, U18)	Texas Instruments	INA239	16 Bit, -40 °C to 125 °C		*
	42-8	AFE (U16)	Texas Instruments	ADS1147	16 Bit, -40 °C to 105 °C		*
	42-9	White Signal Connector (J3)	CHANGJIANG CONNECTORS CO LTD	C4201	600 V, 9 A, -40 °C to 85 °C	UL 1977, CSA-C22.2 No. 182.3	UR (E326732)
	42-9a	White Signal Connector (J3) (alt.)	Interchangeable	Interchangeable	600 V, 9 A, -40 °C to 85 °C	UL 1977, CSA-C22.2 No. 182.3	UR
	42-10	MOSFET (QHL1, QHL9, QHL10)	NIKO	P9006EVA	Vds: 60 V, ld: 3.6 A		*
35, 36		Wall mounting accessory (Optional)	Interchangeable	Material: Steel	Min. thickness: 1.5 mm		*

^{*}Tested as part of apparatus.



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

Page 36 of 55

ANNUAL RE-TESTING OF <u>UNLISTED COMPONENTS</u>

The unlisted components on this page are uncontrolled (not falling under a third party certification program) and require periodic retesting and/or evaluation.

Note to SGS Follow Up Inspector: The inspection office will notify you in writing when these components must be selected and sent to the Lab indicated below for re-evaluation.

Ship the samples to: N/A

The unlisted components covered by this report and are required to be re-tested/evaluated are shown in the following table:

РНОТО #			ITEM#	DES	CRIPTION	MFR		TYPE/ MODEL	RATING
VERIFICA	TION PROC	ESS	•			•			•
Test Standard:									
Frequency of Testing:			No. c	of Test Samp	les:				
Clause No.				PARAMETE	RS				
		•	•		•	•			



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 37 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

MARKINGS

The following markings are required:

Model LX F9.6-30, LX F12.8-30, LX F16.0-30, LX F19.2-30



CAUTION/ATTENTION 1. Do not disassemble the battery. / Ne pas démonter la batterie. 2. Do not immerse the battery in water. / Ne pas démonter la batterie. 3. Do not short-circuit the battery. / Ne pas court-circuiter la batterie. 4. Do not leave the battery nearby fire. / Ne laissez pas la batterie à proximité d'un feu. 5. The battery should be disposed by qualified recycling agent. / La batterie doit être mise au rebut par un agent habilité dans le domaine du recyclage. 6. Use Only Specified Charger. / Utilisez uniquement le chargeur indiqué. 7. Read all instructions before installation, operation and maintenance of the battery system. / Lisez toutes les instructions avant intallation, exploitation et entretien du système de battteries. WARNING/AVERTISSEMENT 1. Risk of Electric Shock. / Risque de choc électrique. 2. Do Not Remove Cover. / Risque de choc électrique. 3. No User Serviceable Parts Inside. / Aucune pièce réparable par l'utilisateur à l'intérieur. 4. Refer Serving to Qualified Service Personnel. / Confiez l'entretien à du personnel agréé pour la maintenance.

Remark:


- 1. Height of SGS Logo shall be min. 5mm.
- Date code: 2269
 - 22 means year, such as 22 means 2022, 23 means 2023, etc.
 - 6 means months, such as 1 means January, 2 means February,, 9 means September, A means October, B means November, C means December.
 - 9 means day, such as 1 means 1st, 2 mean 2nd,, 9 means 9th, A means 10th, B means 11th,, H means 17th, J means 18th,, N means 22th, P means 23th,, X means 31th, from A to X, jumped I and O.
- 3. "P+", "P-" are marked near the polarity of the terminal block of battery system.




GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 38 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

ILLUSTRATION 1 PCB Layout of BCU









GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 39 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025









GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 40 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

ILLUSTRATION 2 PCB Layout of BMU









GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 41 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025








GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 42 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

ILLUSTRATION 3 PCB Layout of DCDC Module







GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415


Page 43 of 55 Issued: 18 Apr. 2024

Revised 03: 29 Apr. 2025

ILLUSTRATION 4 Battery System Overall Dimensions, model LX F9.6-30 (unit: mm)










GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 44 of 55 Issued: 18 Apr. 2024

Revised 03: 29 Apr. 2025

ILLUSTRATION 4

Battery system Overall Dimensions, model LX F12.8-30 (unit: mm)






GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 45 of 55 Issued: 18 Apr. 2024

Revised 03: 29 Apr. 2025

ILLUSTRATION 4

Battery system Overall Dimensions, model LX F16.0-30 (unit: mm)






GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 46 of 55 Issued: 18 Apr. 2024

Revised 03: 29 Apr. 2025

ILLUSTRATION 4

Battery system Overall Dimensions, model LX F19.2-30 (unit: mm)





GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 47 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

ILLUSTRATION 5

Specification

Installation Tool Requirements

The following tools are recommended when installing the equipment. Use other auxiliary tools on site if necessary.



Installation Environment Requirements


- 1. Do not install the equipment in a place near flammable, explosive, or corrosive materials.
- Do not install the equipment in a place that is easy to touch, especially within children's reach. High temperature exists when the equipment is working. Do not touch the surface to avoid burning.
- 3. Avoid thewater pipes and cables buried in the wall when drilling holes.
- Install the equipment in a sheltered place to avoid direct sunlight, rain, and snow. Build a sunshade if it is needed.
- Install the equipment in a well-ventilated place to ensure good dissipation. Also, the installation space should be large enough for operations.
- 6. The equipment with a high ingress protection rating can be installed indoors or outdoors. The temperature and humidity at the installation site should be within the appropriate range.
- 7. Install the equipment at a height that is convenient for operation and maintenance, electrical connections, and checking indicators and labels.
- 8. The altitude to install the equipment shall be lower than the maximum working altitude 3000m (9842ft).



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 48 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

ILLUSTRATION 5 Specification



Label Description

Label Description							
\triangle	Potential risks exist. Wear proper personnel protective equipment before any operations.		Install the equipment away from fire sources.				
A	HIGH VOLTAGE HAZARD High voltage exists during the equipment's running. Ensure the equipment is power off before any operations.		Keep the equipment away from children.				
	Operate the equipment properly to avoid explosion danger.		It is forbidden to dismantle the equipment personally.				
	The equipment contains corrosive electrolytes. In case of a leak in the equipment, avoid contact the leaked liquid or gas.		Do not short-circuit the positive and negative pole of the equipment. Otherwise it may cause damage to the cables.				
	Batteries contain flammable materials, beware of fire.		Grounding point.				
	Read through the user manual before any operations.	SGS 800923	SGS marking for United States and Canada				



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 49 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

ILLUSTRATION 5

Specification

4.3 Storage

If the equipment is not to be installed or used immediately, please ensure that the storage environment meets the following requirements:

- 1. Do not unpack the outer packing box or throw the desiccant away.
- 2. Complete the equipment installation in three days after unpacking it. Pack and store the equipment using the original packing box if it is not installed.
- 3. Stack the equipment complying with the labels and requirements on the packing box.
- 4. The equipment must be stacked with caution to prevent them from falling.
- 5. Keep the equipment away from flammable, explosive, and corrosive matters.
- 6. Place the equipment in a cool place where away from direct sunlight.
- 7. Store the equipment in a clean place. Make sure the temperature and humidity are appropriate and no condensation.
- 8. Storage SOC: 25%~50% SOC. Circle the charge-discharge every 6 months.
- 9. Recommended storage temperature: 0°C~35°C (less than one year), -20°C~0°C or 35°C~45°C(less than one month).
- 10.Recommended storage humidity: 0%~95%RH (no condensation). Do not install the battery if there is any moisture or condensation.

5 System Installation

5.1 Installation Requirements

Installation Environment Requirements

- 1. Do not install the equipment in a place near flammable, explosive, or corrosive materials.
- 2. Do not install the equipment in a place that is easy to touch, especially within children's reach. High temperature exists when the equipment is working. Do not touch the surface to avoid burning.
- 3. Avoid thewater pipes and cables buried in the wall when drilling holes.
- Install the equipment in a sheltered place to avoid direct sunlight, rain, and snow. Build a sunshade if it is needed.
- 5. Install the equipment in a well-ventilated place to ensure good dissipation. Also, the installation space should be large enough for operations.
- 6. The equipment with a high ingress protection rating can be installed indoors or outdoors. The temperature and humidity at the installation site should be within the appropriate range.
- 7. Install the equipment at a height that is convenient for operation and maintenance, electrical connections, and checking indicators and labels.
- 8. The altitude to install the equipment shall be lower than the maximum working altitude 3000m (9842ft).



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 50 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

ILLUSTRATION 5

Specification

6 Electrical Connection 6.1 Safety Precaution

DANGER(DANGER)

INSTRUCTIONS PERTAINING TO A RISK OF FIRE OR ELECTRIC SHOCK

- Perform electrical connections, including operations, cables, and component specifications in compliance with local laws and regulations ANSI/NFPA 70.
- The battery system exists high voltage during the equipment running. Please keep Power
 Off before any operations to avoid danger. Strictly follow all safety precautions outlined in
 this manual and safety labels on the equipment during the operation.
- All operations, cables and parts specification during the electrical connection shall be in compliance with local laws and regulations.
- Tie the same type cables together, and place them separately from cables of different types.
 Do not place the cables entangled or crossed.
- When crimping the terminals, ensure that the conductor part of the cable is in full contact with
 the terminals. Do not crimp the cable jacket with the terminal. Otherwise the charger may
 not operate, or its terminal block getting damaged due to heating and other phenomenon
 because of unreliable connection after operation.

INSTRUCTIONS CONCERNANT LES RISQUES D'INCENDIE OU D'ÉLECTROCUTION

- Effectuez les connexions électriques, y compris les opérations, les câbles et les spécifications des composants, conformément aux lois et réglementations locales ANSI/NFPA 70.
- Le système de batterie présente une haute tension pendant le fonctionnement de l'équipement. Veuillez couper l'alimentation avant toute intervention pour éviter tout danger. Suivez strictement toutes les précautions de sécurité décrites dans ce manuel ainsi que les étiquettes de sécurité sur l'équipement pendant l'opération.
- Toutes les opérations, les câbles et les spécifications des pièces lors de la connexion électrique doivent être conformes aux lois et réglementations locales.
- Attachez les câbles de même type ensemble et placez-les séparément des câbles de types différents. Ne laissez pas les câbles s'entremêler ou se croiser.
- Lors du sertissage des bornes, assurez-vous que la partie conductrice du câble est en contact complet avec les bornes. Ne serrez pas la gaine du câble avec la borne. Sinon, le chargeur pourrait ne pas fonctionner, ou son bornier pourrait être endommagé en raison d'un échauffement ou d'autres phénomènes dus à une connexion peu fiable après l'opération.



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 51 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

ILLUSTRATION 5

Specification

NOTICE(AVIS)

- Wear personal protective equipment like safety shoes, safety gloves, and insulating gloves during electrical connections.
- · All electrical connections should be performed by qualified professionals.
- Cable colors in this document are for reference only. The cable specifications shall meet local laws and regulations.
- Portez des équipements de protection individuelle (EPI) tels que des chaussures de sécurité, des gants de protection et des gants isolants lors des connexions électriques.
- · Toutes les connexions électriques doivent être réalisées par des professionnels qualifiés.
- Les couleurs des câbles mentionnées dans ce document sont données à titre indicatif uniquement. Les spécifications des câbles doivent être conformes aux lois et réglementations locales.

8.2 Routine Maintenance

⚠ WARNING(AVERTISSEMENT)

- Contact the after-sales service for help if you find any problems that may influence the battery or the hybrid inverter. Disassemble without permission is strictly forbidden.
- Contact after-sale service for help if the copper conductor is exposed. Do not touch or disassemble privately because the high voltage danger exists.
- In case of other emergencies, contact the after-sales service as soon as possible. Operate following the instructions or wait for the after-sales service personnel.
- En cas de problème susceptible d'affecter le système de batterie ou l'onduleur de stockage, veuillez contacter le service après-vente. Il est strictement interdit de procéder à un démontage sans autorisation.
- Si des fils de cuivre internes du conducteur électrique sont exposés, ne les touchez pas (danger de haute tension), contactez le service après-vente et ne procédez pas à un démontage sans autorisation.
- En cas d'autres situations d'urgence, contactez immédiatement le service après-vente et suivez ses instructions ou attendez l'intervention sur place du personnel après-vente.



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 52 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

ILLUSTRATION 5

Specification

Maintaining Item	Maintaining Period
Checkwhether the locking bracket is secured, tighten it if not.	Once every 6 months
Check whether the outer enclosure is broken. Repair the painting or contact the after-sales service if there is any broken.	Once every 6 months
Check whether there is an exposed cable. Replace the exposed cable or contact the after-sales service for help.	Once every 6 months
Check whether there is any dust around the battery module. Clean the dust if there is any to avoid affecting heat dissipation.	Once every 6 months
Check whether there is any liquid or pest near the battery to avoid intrusion in a long term.	Once every 6 months

8.3 Recycling and Disposal

It is forbidden to dispose of used batteries at will, and the disposal of used batteries shall comply with the laws and regulations of each federation.



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 53 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

SUMMARY OF TEST RESULTS

The following tests were performed:

Standard for Safety for Batteries for Use in Stationary and Motive Auxiliary Power Applications, ANSI/CAN/UL 1973:2022, Third Edition, Dated February 25, 2022.

rippiioationo, rii to	" 0, 11, 02 10, 0,2022, 11ma 2amon, Datod 1 05, daily 20, 2022.
<u>Section</u>	<u>Test Description</u>
15	Overcharge Test
16	High Rate Charge
17	Short Circuit Test
18	Overload Under Discharge
19	Overdischarge Protection Test
20	Temperature and Operating Limits Check Test
21	Imbalanced Charging Test
22	Dielectric Voltage Withstand Test
23	Continuity Test
25	Working Voltage Measurements
27	Electromagnetic Immunity Tests
31	Static Force test
32	Impact test
33	Drop Impact Test
34	Wall Mount Fixture/Support Structure/Handle Test
35	Mold Stress Test
39	Resistance to Moisture Test
40	Salt Fog Test
42	Single Cell Failure Design Tolerance
	Section 15 16 17 18 19 20 21 22 23 25 27 31 32 33 34 35 39 40

The following tests were performed to the transformers, model 140-00193-00 by Liangfeng and model 140-00193-00 by JTK on DC/DC module:

Standard for Safety for Batteries for Audio/Video, Information and Communication Technology Equipment – Part 1: Safety Requirements, UL 62368-1, CAS C22.2 No.

62368-1:19, Third Edition, Dated December 13, 2019

Section Test Description

5.4.2, 5.4.3, 5.4.4.5 a), b) Minimum Clearances/Creepage distance

5.4.9 Electric Strength test

6.4(B.3-B.4) Abnormal Operating and Fault Conditions Test

Results of the tests indicate the specimens conform to the test criteria that were found to be applicable.



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 54 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

REVISION TABLE

The following changes have been made to this Report:

Revision No.	<u>Date</u>	Project #	Revision prepared by	<u>Page</u>	Description of Change	
00	2024- 04-18	CQES2 401000 034BA	Brian Han	-	-	
01	2024- 05-30	CQES2 401000 034BA	Kyle Tian	3	Add test location of EMC tests	
	2024-	CQES2 407000 611BA	Kyle Tian	1	Change Contact Details and Factory address	
	08-20			3	Change Altitude from 2000 m to 3000 m	
				27	Correct Photo 36 of Wall mounting schematic diagram	
				30	Correct Balanced resistance manufacturer to "UNI-ROYAL"	
				42	Correct layout of DCDC	
03	2025- 04-29	CQES2 504000 389BA	Kyle Tian	3	Change IP rating from IP55 to IP65	
				19, 20	Correct photo name from BMS to BCU	
				37	Revise the IP rating on battery system label	
				49 to 52	Add instructions	



GoodWe Technologies Co., Ltd. PROJECT NUMBER: SZ-CERT240401415

Page 55 of 55 Issued: 18 Apr. 2024 Revised 03: 29 Apr. 2025

CONCLUSION

Samples of the products covered by this Report have been found to comply with the applicable requirements of Stationary and Motive Auxiliary Power Application, ANSI/CAN/UL1973:2022, Third Edition, Dated February 25, 2022.

Report Prepared by:

Kyle Tian Engineer

Report Approved by:

Certification Reviewer