

TOP RACK TECHNOLOGY, INC FIRE TEST REPORT

SCOPE OF WORK

UL 2703 TESTING ON TOP RACK TECHNOLOGY, INC STEEP SLOPE RACKING SYSTEM

REPORT NUMBER

106017786MID-001

TEST DATES

12/12/24 - 01/07/25

ISSUE DATE

01/28/25


PAGES

24

DOCUMENT CONTROL NUMBER

RT-R-AMER-Test-2847 (03/07/18)

© 2017 INTERTEK



TEST REPORT FOR TOP RACK TECHNOLOGY, INC

Report No.: 106017786MID-001

Date: 01/28/25

REPORT ISSUED TO

TOP RACK TECHNOLOGY, INC

355 New Albany Road
Suite B
Moorestown, NJ 08057
USA

Contact: Michael Orshan

E-mail: michael.orshan@topracktech.com

SECTION 1

SCOPE

Intertek Testing Services NA, Inc. was contracted by Top Rack Technology, Inc to evaluate the fire performance of the assembly described in Section 5 of this report. Testing was conducted at the Intertek B&C test facility in Middleton, WI. Results obtained are tested values and were secured by using the designated test method. A summary of test results is reported herein, and the complete assembly construction details are included in this report.



This report does not constitute certification of this product nor an opinion or endorsement by this laboratory. Intertek B&C will service this report for the entire test record retention period. The test record retention period ends four years after the test date. Test records, such as detailed drawings, datasheets, representative samples of test specimens, or other pertinent project documentation, will be retained for the entire test record retention period.

Unless differently required, Intertek reports apply the "Simple Acceptance" rule, also called "Shared Risk approach," of ILAC-G8:09/2019, Guidelines on Decision Rules and Statements of Conformity.

SECTION 2

SUMMARY OF TEST RESULTS

For INTERTEK B&C:

COMPLETED BY:	Seth Newman	REVIEWED BY:	Chad Naggs
TITLE:	Technician	TITLE:	Technical Team Lead –
DEPARTMENT:	Fire Resistance	DEPARTMENT:	Fire Resistance
SIGNATURE:		SIGNATURE:	
DATE:	01/28/25	DATE:	01/28/25

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

TEST REPORT FOR TOP RACK TECHNOLOGY, INC

Report No.: 106017786MID-001

Date: 01/28/25

SECTION 2 (CONTINUED)

SUMMARY OF TEST RESULTS

DECK #	TYPE OF TEST	SLOPE	MODULE TYPE	RESULTS
1	Class 'A' Burning Brand (Top of Panel).	Steep Slope	Type 2	Pass
2	Class 'A' Burning Brand (Top of Panel).	Steep Slope	Type 2	Pass
3	Class 'A' Burning Brand (Top of Panel).	Steep Slope	Type 2	Pass
4	Class 'A' Burning Brand (Top of Panel).	Steep Slope	Type 2	Pass
5	Class 'A' Spread of Flame.	Steep Slope	Type 2	Pass
6	Class 'A' Spread of Flame.	Steep Slope	Type 2	Pass
7	Class 'A' Spread of Flame.	Steep Slope	Type 2	Pass
8	Class 'A' Spread of Flame.	Steep Slope	Type 2	Pass
9	Class 'A' Burning Brand (Top of Panel).	Steep Slope	Type 1	Pass
10	Class 'A' Burning Brand (Top of Panel).	Steep Slope	Type 1	Pass
11	Class 'A' Burning Brand (Top of Panel).	Steep Slope	Type 1	Pass
12	Class 'A' Burning Brand (Top of Panel).	Steep Slope	Type 1	Pass
16	Class 'A' Spread of Flame.	Steep Slope	Type 1	Pass
17	Class 'A' Spread of Flame.	Steep Slope	Type 1	Pass
18	Class 'A' Spread of Flame.	Steep Slope	Type 1	Pass
19	Class 'A' Spread of Flame.	Steep Slope	Type 1	Pass
20	Class 'B' Burning Brand.	Steep Slope	Type 1	Pass
21	Class 'B' Burning Brand.	Steep Slope	Type 1	Pass
22	Class 'B' Burning Brand.	Steep Slope	Type 1	Pass
23	Class 'B' Burning Brand.	Steep Slope	Type 1	Pass



Total Quality. Assured.

8431 Murphy Drive
Middleton, Wisconsin 53562

Telephone: 608-836-4400
Facsimile: 608-831-9279
www.intertek.com/building

TEST REPORT FOR TOP RACK TECHNOLOGY, INC

Report No.: 106017786MID-001

Date: 01/28/25

SECTION 9

REVISION LOG

REVISION #	DATE	PAGES	REVISION
0	01/28/25	49	Original Report Issue